

APPLICATION No.: 11499

TAP CLEARED 8911-2488

LOCATION: 81 Field St.

OWNER: Serafim Silva

MEASURES: 3/4" Copper Sept. 18, 1906

S from Matthew St. 22.3 ft.

E from W line Field St. 8.8 ft.

S from N line office 12.3 ft.

Nov. 7, 1958 Repaired a leak by renewing from property line to inside cellar.

Stock supplied and installed by owner's plumber

28 ft. of 3/4" copper tubing type K, soft

Rebeiro

Prenda

Dec. 15, 1958 Renewed from a point $1\frac{1}{2}$ ft. outside curb stop to a point 2 ft. inside curb stop $3\frac{1}{2}$ ft. of $3/4"$ copper tubing
 $3/4"$ cop. to cop. stop, fig. 415 2 lbs. wiping solder

July 24, 1974 Renewed from the curb stop to the property line.

8 ft. - 3/4" Copper tubing
Caldwell Stop Box

5/8" lead to copper
adaptor XXS

3/13/87: Renewed from 1.0ft. outside prop line to 2.0 ft. inside prop. line. Stock: 3.0ft. 3/4" copper tubing 2-3/4 x 3/4 cop to cop cplg.

comp. NOTE: copper runs straight to prop line then is heading south

NOTE: 2.0 lead left between 1958 work inside prop, & 1974 outside.

NOTE. 2.
BRADBURY-WARING, INC.

5/18/

[illegible]

11499

81 Field St

APPLICATION No.:

LOCATION:

OWNER:

31-313

MEASURES:

7/18/12 - City crew renewed water service from main to
curb stop (tap leak)

10 ft - 3/4" copper tubing; 1 - 3/4" curb stop;

1 Caldwell stop box; 1 - 3/4" x 3/4" Fig 413; Tap cleaned

Foreman: Jarred Medeiros

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

[illegible]