

APPLICATION No.: 11509

## TAP CLEARED

LOCATION: 51 Independent St

DATE

BEF.

AFT.

REMARKS

OWNER:

10/21/75

31-313

MEASURES:

Sept 12, 1906

E X Crapo St 338.0 ft

S X N Line Independent St 8.4 ft

E X W Line House 8.1 ft

1" Copper Service

11/28/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 24

Distance from curb stop to meter (ft) 19

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 3.9

Total length of new pipe installed (ft) 24

Curb stop repalced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: no size 3/4"

Remarks: 1-3/4" union installed 1LF outside  
curb stop

[illegible]