

APPLICATION No.: 11522

## TAP CLEARED

LOCATION: 416 Orchard St

OWNER:

31-313

MEASURES: Sept 19, 1906

N X Thompson St 73.2 ft

W X E Line Orchard St 9.5 ft

N X S Line House 10.6 ft

1" Copper Service

12/04/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 98

Distance from main to curb stop (Ft) 25.8

Distance from curb stop to meter (ft) 13

Distance from curb face to curb stop (ft) 2

Depth of service (ft) 4.1

Total length of new pipe installed (Ft) 25.8

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: No size 3/4"

Remarks: 1-3/4 union installed LF outside curb stop

DATE

BEF.

AFT.

REMARKS

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

## CHARGE OUTS

