

11526

LOCATION:

31-313

MEASURES:

N from N line Orchard St	95.3
W from E line Dartmouth St	7.0
W from E line Building	12.0
E from W line Building	21.0
N from N line Building	85.0
Main to Property Line	85.0
Pipe inside Property	77.0

7/17/12 - Chris Mendoza renewed this water service from a point 5 ft inside property line to building - Owner charged \$115 (\$70 inspection fee, \$45 turn-on)
Inspected by Percy

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 11526

LOCATION: ~~12 Dartmouth St.~~

OWNER: Shell Oil Co.

MEASURES: 5/8" H. lead Oct. 5, 1906

N from	Orchard St.	95.3 ft.
W from E line	Dartmouth St.	7.0 ft.
S from N line	Bldg.	7.3 ft.

July 14, 1969 Renewed curb stop to prop. line.
14 ft. - 3/4" Copper 1 wipe joint
3/4" x 3/4" Eop to cop cplg. 3/4" curb stop
(at property line)

June 16, 1977: Renewed from main to curbstop; 59 ft.-3/4" copper; 1-5/8" x 3/4" Fig. 413; tap reamed; stop box;

Taps Allen S t. main 68 ft. E. of Orchard St.
Laid in trench with drain.

4/1/91 reading. Linda

3/29/91 shut off at curb stop - boarded - cannot removed meter.

3/31/92 checked - still off at curb stop - A. Hunt

Must bring copper in to house from property line before this service can be turned on.

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

6/16/77

Tap reamed

[illegible]

CHARGE OUTS

[illegible]