

APPLICATION No.: 11534

LOCATION: 103 Jouvette St

TAP CLEARED

OWNER:

31-313

MEASURES: Oct 2, 1906

E X Crapo St 61.7 ft

S X N Line Jouvette St 9.0 ft

E X W Line House 6.8 ft

1" Copper Service

08/01/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 24

Distance from curb stop to meter (ft) 14

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 5

Total length of new pipe installed (ft) 38

Curbstop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: yes size 1"

DATE

BEF.

AFT.

REMARKS

1/12/90 Ream

[illegible]