

APPLICATION No.: 11595

TAP CLEARED



LOCATION: 202 Tinkham

OWNER: Francisco A. DeMoura

MEASURES: 5/8"

W from	Aoushnet Ave.	241.6 ft.
N from S line	Tinkham	9.5 ft.
E from W line	house	12.1 ft.

-----  
September 26, 1949 Leak at the tap. No stock used.-----  
Oct. 17, 1978: Renewed 6" outside to 18" inside curbstop.  
2 ft.-3/4" copper; 2-5/8" x 3/4" lead to cop. adapt. XS;  
Caldwell stop box; 3/4" curb stop;4/11/79: Franklin Const. renewed service from the main to the meter.  
24 ft.-3/4" copper (6' ins.); 3/4" curb stop; 1-Caldwell stop box;  
5/8" x 3/4" Fig. 413;

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]