

11619

✓

TAP CLEARED

**OWNER:**

31-313

107.5 ft

N X S Line Tinkham St 9.5 ft

E X W Line House 7.5 ft

```
1" Copper Service 5/15/2018
Lead Service Line Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 70
Distance from main to curb stop (Ft) 10.6
Distance curb stop to meter (ft) 17
Distance from curb face to curb stop (ft) 2
Depth of service (ft) 4.5
Total length of new pipe installed (ft) 10.6
Curb stop replaced: Yes size 1"
Corporation replaced: Yes size 1"
Ball Valve replaced: No size 3/4"
Remarks: 3/4"-1" union installed 1' from curb
stop
```

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

2/2/96	Reamed
--------	--------

8/21/96 Reamed

[illegible]