

11623



154 Erenia

Arthur M. Beaulieu

5/8th

W from

Front

131.0

N from S line

Eugenia

9.0

"W from E line

House

17.0

Sept. 15, 1994 Could not get on curb stop. Removed old stop box &
installed a new stop box.
1 Caldwell Stop box, compl.

Lead serv.replacement

April 10, 1997 Renewed from main to ins.cellar (8.0ft ins.

prop line) Stock: 26.0ft 3/4" copper tubing 1-3/4" curb stop
re-used Caldwell stop box 1-3/4x5/8 Fig 413

[illegible]

METER HISTORY

[illegible]

CHARGE OUTS