

656 APPLICATION No.: 11646 10" Cast Iron

TAP CLEARED

LOCATION: Belleville Ave. E.S. N. Of Belleville Rd.

DATE

BEF.

AFT.

REMARKS

OWNER: Nonquitt Mill #1

FIRE SUPPLY

MEASURES: 10" Cast Iron May 17, 1907
 10" Chap. gate
 S from Hatch 89.3 ft.
 W from E line Belleville Ave. 13.3 ft.
 N from N line Nonquitt Mill #1 32.4 ft.
 Gate in Wood box.
 FIRE SUPPLY

1976 Installed 10" Tapping sleeve Mueller & 10" tapping
 gate Mueller for Community line:

Measure of 10" tapping sleeve:

S x S line Hatch St. 87 ft.
 E x W line Belleville Ave. 40.5 ft.

Measure for 10" Tapping gate Mueller:

S x S line Hatch St. 88.6 ft.
 E x w line Belleville Ave. 40.5 ft.

CAMARA

Oct. 4, 1991 Replaced operating nut on 10" fire supply gate valve.
 Billed to Fibre Leather on Misc. Bill

METER HISTORY

[illegible]

CHARGE OUTS