

APPLICATION No.:		TAP CLEARED			
LOCATION:	DATE	BEF.	AFT.	REMARKS	
330 No. Front					
OWNER: Hermine Rousseau					
MEASURES:					
5/8"					
S from Nye 90.0					
W from E line Front 8.5					
On S line House					
June 7, 1977: Renew 1/2 ft. outside curbstop to the line. 10 ft.-					
3/4" copper; 3/4" curbstop; stop box; 2-5/8" x 3/4" lead connector					
3;					
11/2/78: Franklin Const. renewed service from the main					
to the property line. 32 ft.-3/4" copper; 5/8" x 3/4"					
Fig. 413; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4"					
lead-cop. adapt.					
May 30, 1986 Owner called has leak before meter -					
insists that the city should repair it. Refuses to repair					
it. I informed him that meter reader would check it &					
send a letter & ultimately would be shut off!!					
9/26/16 lead renewal from c/s to meter					
20 ft 3/4" copper tubing					
lead worker: Ronald Aguiar DPI					

[illegible]

CHARGE OUTS