

APPLICATION No.: 11713

TAP CLEARED

LOCATION: 45 Ashley St.OWNER: Mary B. NunesMEASURES: 5/8" H lead May 31, 1907S from Ruth St. 242.3 ft.E from W line Ashley St. 9.0 ft.N from S line house 10.7 ft.June 16, 1961 Renewed from main to  $\frac{1}{2}$  ft. inside curb stop.10 $\frac{1}{2}$  ft. -  $\frac{3}{4}$ " copper tubing; 1- $\frac{3}{4}$ " cop to cop stop, fig. 415; 1# wiping solder; 1- $\frac{5}{8}$ " reused corp. cplg. Tap reamed.  
- - -8/24/06 Renewed from main to inside cellar. (6 ft. inside prop line) Stock: 18 ft.  $\frac{3}{4}$ " copper tubing;  $\frac{3}{4}$ " curb stop; Caldwell stop box;  $\frac{5}{8}$ " x  $\frac{3}{4}$ " Fig. 413 Tap reamed  
Also repaired broken sewer & drain. Stock: 2 - 6" Ferncos clay-plastic; 5 ft. 6" PVC pipe  
-----

DATE

BEF.

AFT.

REMARKS

6/16/61

Reamed

8-24-06

2006-340-7573

8/24/06

Tap reamed

## METER HISTORY

## CHARGE OUTS

[illegible]