

APPLICATION No.: 11795

TAP CLEARED

LOCATION: 241 Tremont

OWNER: Ray Lucardi

7/3/1907

MEASURES: 5/8" 3/4"

Copper

S from

Rempton

150.0 ft.

E from W line

Tremont

7.5 ft.

S from N line

house

2.5 ft.

April 8, 1976 Renewed from 6" outside curb stop to property line.

6 1/2 ft. - 3/4" Copper tubing 3/4" Curb Stop

Caldwell Stop Box

- 2 - 5/8" x 3/4" lead to copper
adaptor XS

July 20, 1988 removed meter - to check pressure - Pressur O.K.

8/5/88: Renewed from main to inside cellar.(9 ft. ins. prop line)

Stock: 27 ft. 3/4" copper tubing 1-3/4" curb stop

1-3/4x5/8 Fig.413

=====

Check out for poor pressure & K up to

meter 10/3/89

6/6/05 Renewed from newly installed 8" main to a point 8.0 ft.

Stock: 8.0 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop cplg., comp;

3/4" Corp. tap

Silva Cont.

DATE

BEF.

AFT.

8-5 REMARKS

8831-4632

8/5/88: TAP REAMED

[illegible]

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some minor discoloration and small dark spots, possibly due to age or handling. A vertical crease is visible near the left edge, suggesting it was once part of a bound volume. The overall tone is a warm, off-white or light beige.