

APPLICATION No.: 11815

TAP CLEARED

LOCATION: 146 Rockland St

DATE

BEF.

AFT.

REMARKS

OWNER:

3/27/78

31-313

July 17, 1907

MEASURES:

E X Briggs St 69.2

N X S Line Rockland St 7.5 ft

E X W Line House 11.6 ft

1" Copper Service

10/23/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 95

Distance from main to curb stop (ft) 7

Distance from curb stop to meter (ft) 24

Distance from curb stop to curb face (ft) 1.5

Depth of service (ft) 4

Total length of new pipe installed (ft) 31

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: Yes size 1"

[illegible]