

APPLICATION No.: 11829

TAP CLEARED

LOCATION: 24 Salisbury St.OWNER: Zulmira SouzaP.15-6.140

DATE

BEF.

AFT.

REMARKS

MEASURES:

 $\frac{1}{2}$ "

H lead

July 23, 1907

N from

Ruth St.

230.0 ft.

W from E line Salisbury St.

9.5 ft.

N from S line house

7.4 ft.

7/25/79: Renewed 6" outside curbstop to 6 ft. inside
curb stop. 6½ft. - ¾" copper; ¾" curbstop; Caldwell stop
box; 2-5/8" x ¾" lead-cop. adapt. XS;

4/1/81: Bldg. boarded up Could not get in bldg
owners name Albert Jamaitis

9/16/91: Renewed from main to curb stop Stock: 20ft.

¾" copper tubing same curb stop 1-Caldwell stop box

1- ¾" corp.tap 1-6x¾" service saddle

1" Copper Service

03/27/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 21.5

Distance from curb face to curb stop (ft) 2

Depth of service (ft) 4

Total length of new pipe installed (ft) 21.5

Curb stop replaced: NO, Corporation Replaced: NO

Ball valve replaced: Yes size 1"

9/16/91: TAP REAMED

[illegible]

CHARGE OUTS

