

APPLICATION No.: 11837

TAP CLEARED

LOCATION: 24 Margin St

OWNER:

31-313

MEASURES: July 17, 1907

S X Cove St 146.8 ft

W X E Line Margin St 7.2 ft

S X N line House 11.0 ft

1" Copper Service

05/14/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from curb stop to main (ft) 20

Distance from curb stop to meter (ft) 14.5

Distance from curb face to curb stop (ft) 2.3

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 14.5

Curb stop replaced: no, size 3/4"

Corporation replaced: no size 3/4"

Ball valve replaced: yes size 1"

Remarks: 1-3/4" union installed 1FT outside
curb stop

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

