

APPLICATION No.: 11855

TAP CLEARED 8332 04/7

LOCATION: 915 Rockdale Ave., N.W. Cor. of Rogers

OWNER: Barry L Mikens

MEASURES:	3/4"	L lead	8-12-1907
	N from	Rogers	22.0 ft.
	E from W line	Rockdale Ave.	6.6 ft.
	NZ from S line	House	2.2 ft.

July 30, 1971 Renewed from left. outside curb stop to a point  
3 ft. to second curb stop.  
3 ft. of 3/4" copper tubing            2 3/4" Hays curb stop  
2 wipe joints

December 23, 1975      Renewed from the main to 1 ft. in front of the main.  
1 ft. 3/4" copper tubing      1 3/4" x 3/4" Fig. 413  
1 3/4" x 5/8" lead to copper adaptor      XKS

Aug. 9, 1983 Renewed from curb stop to inside of  
cellar (by owner).  
25'-3/4" copper tubing (20 ft. ins.)  
1-3/4" curb stop 1-Stop box

1/2/07 Renewed from main to curb stop. Stock: 10 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 3/4" x 3/4" cop-cop cplg., comp.

Tap reamed Monty

See attached card

[illegible]

[illegible]

## CHARGE OUTS

[illegible]



11855

APPLICATION No.:

LOCATION: 915 Rockdale Ave., N.W.C. of Rogers St

OWNER:

31-313

MEASURES:

7/8/08 - West End Water Main rehab Contract #4 - Perrina Const.  
Renewed service from main to a point 25 ft  
25 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer  
Inspected by Tim Ives, CDM  
-----

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

[illegible]