

APPLICATION No.: 11931

TAP CLEARED

LOCATION: 31 Jouvette St

OWNER:

31-313

MEASURES: Oct. 19, 1907
W X County St 320.0 ft
S X N Line Jouvette St 9.0 ft
E X W Line House 12.6 ft
1" Copper Service
09/18/2019 Lead Service Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 100
Distance from main to curb stop (ft) 24.9
Distance from curb stop to meter (ft) 13.0
Distance from curb face to curb stop (ft) 2.9
Depth of service (ft) 4.3
Total length of new pipe installed (ft) 24.9
Curb stop replaced: yes size 1"
Corporation replaced: yes size 1"
Ball valve replaced: no size 3/4"
Remarks: 1-3/4 union installed where shown

DATE

BEF.

AFT.

REMARKS

[illegible]