

APPLICATION No.: 11967 5/8"

TAP CLEARED 9048-4001

LOCATION: 61 Bullard St.

OWNER: Angelo C. De Mello

MEASURES: 5/8"

E from

Acushnet Ave.

115.0 ft.

S from N line

Bullard

8.5 ft.

W from E line

House

2.5 ft.

9/28/78: Franklin Const. renewed service from the main to the prop. line. 32 ft. - 3/4" copper; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XXS

11/30/90: Renewed from curb stop to ins. cellar

5 ft. ins. prop line ===== Stock: 15ft. 3/4" copper tubing

*Complained of poor pressure 4/4/91 O.K. checked by Mr. Roe.*

*Very good pressure 5/30/91 Decato*

*Complained Low Pressure 4/12/94 - BEN TO checked 4-13-94*

*HOUSE HAS 75 P.S.I. AT METER.*

DATE

BEF.

AFT.

REMARKS

[illegible]