

APPLICATION No.: 11971

TAP CLEARED

LOCATION: 900 Rockdale Ave.

OWNER: Frank H & R.D. Spooner

DATE

BEF.

AFT.

REMARKS

12/29/77

Tap Reamed

MEASURES:

3/4"

N from

Milton

48.0 ft.

W from E line

Rockdale Ave.

7.8 ft.

N from S line

House

10.0 ft.

12/29/77: Renewed from main to a point 2½ ft. from main.

2½ ft.-3/4" copper; 3/4" x 3/4" lead to cop. adapt. XS;

3/4" x 3/4" Fig. 413; - - - - -

1/30/80: Renewed from 6" outside curbstop to the property

line. 5.5 ft.-3/4" copper 3/4" curb stop; stop box;

2-5/8" x 3/4" lead-cop. adapt. XXS;

7/15/08 - West End Water Main rehab Project -Contract #4

Perrina Construction renewed service from main to a point

38 ft with 1" copper tubing; then curb stop to a point

13 ft outside curb stop with 3/4" copper tubing;

1" Corp tap. Inspected by Tim Ives, CDM

[illegible]