

APPLICATION No.: 11977

## TAP CLEARED

LOCATION: 6 Sears St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

Nov. 12, 1907

MEASURES:

S X Washington St

62.4 ft

W X E Line Sears St

7.5 ft

N X S Line House

7.5 ft

12/5/2018 Lead Service Replacement Program

1" Copper Service

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 98

Distance from main to curb stop (ft) 6

Distance from curb stop to meter (ft) 17.6

Distance from curb face to curb stop (ft) 1.8

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 17.6

Curb stop replaced: NO size 3/4"

Corporation replaced: No size 3/4"

Ball valve replaced : Yes size 1"

Remarks: 1-3/4 union installed 1LF outside  
curb stop

8/20/57 Ream

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
	Ties:								

Hand-drawn site plan on graph paper. The plan shows a property labeled "ID 29-167" adjacent to "C 5 EARS STREET". A "PICTER" is marked with a square. A "CURB" and "SIDEWALK" are indicated on the right side. A "DENSE" area is marked with a dot. Distances are noted: "20.3" and "23.6". A north arrow is present.

Ties: