

11984

✓

TAP CLEARED

OWNER:

DATE _____

BEF.

AFT.

REMARKS

8/4/65	Reamed
--------	--------

31-313

28.0 ft

9.5 ft

22.0 ft

1"Copper Service 05.16.2018

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 72

Distance from main to curb stop (Ft) 9

Distance from curb stop to meter (ft) 19.2

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.1

Total length of new pipe installed (ft) 19.2

Curb stop replaced: No size 3/4"

Corporation replaced: No size 3/4"

Ball Valve replaced: Yes size 1"

Remarks: 3/4"-1" union installed 1" from curb
stop

[illegible]