

12010

APPLICATION No.:

LOCATION: 281-283 Ashley Blvd (Bowditch)

TAP CLEARED

OWNER:

'31-313

MEASURES:

Jan 6, 1908

W from Bowditch 52.0'

S from N Line Collette 8.5'

E from W line House 3.0'

1" COPPER

7-10-18: Lead service line replacement program
phase 1: TYPE CU, Diameter 1, Water Pressure 75

Distance from main to curb stop: 23.4'

Distance curb stop to meter 11.0'

Distance from curb face to curb stop 1.5'

Depth of service 4.3'

Total length of new pipe installed 27.4'

Curb stop replaced: NO Size 3/4"

Corporation replaced: NO Size 3/4"

Ball Valve furnished: YES Size 1"

Remarks: 1" - 3/4" Union installed 4.0 LF
outside curb stop

DATE

BEF.

AFT.

REMARKS

1-14-89 Tap reamed

[illegible]

CHARGE OUTS

