

LOCATION: 577 Belleville Ave.

OWNER: A Katz

MEASURES: 5/8" 1" H lead Jan. 28, 1908  
 S from Whitman 7.0 ft.  
 E from W line Belleville Ave. 9.2 ft.  
 S from N line Bldg. 5.0 ft.

DATE

BEF.

AFT.

REMARKS

11/22/72

Reamed

3/25/86: TAP REAMED

4/24/05 4:30 PM 2005-181-2803  
 SEWER

Sept. 30, 1953 Renewed from curb stop to inside cellar.  
 8 1/2 ft. - 3/4" copper tubing; 1# wiping solder;

Nov. 22, 1972 Renewed from the main to a point 1 ft.  
 from the main.  
 1 ft. - 3/4" Copper tubing 1 wipe joint  
 3/4" x 3/4" Fig. 413

Measures for 1" Tap:

S x S Line Whitman St. 14.6 Ft.  
 W x E Line Belleville Ave. 9.3 Ft.

Oct. 18, 1976 - Zoppo Const. installed a 1" tap during  
 the installation of 48" main.

1 - 1" Ford Tap

3/25/86: Renewed from main to curb stop. Stock: 12.0 ft.  
 3/4" copper tubing 1 - 3/4" curb stop 1 - Caldwell  
 stop box 1 - 3/4x5/8 Fig. 413.

=====

5/27/03 Due to constant dirty water complaints, this service was tied into 48" main.

Removed from 12" main and tied into the 48" main using existing 1" tap on 48" main with a  
 1 1/4" x 3/4" Fig. 413; 3/4" x 3/4" cop to cop cplg;

Main is 42' ex curb stop 3 ft - 3/4" copper tubing

## METER HISTORY

## CHARGE OUTS

[illegible]