

12081



LOCATION: 1-3 BAY ST

OWNER: JULES & MARY PACHECO

MEASURES: 5/8" H.LEAD APRIL 28 1908

N FROM BAY ST 1.0 ft

E FROM W LINE DARTMOUTH ST 7.5 ft

N FROM E LINE MAIN HOUSE 3.8 ft

Oct 15, 1997:

Street reconstruction: Renewed from main to prop line

Stock: 34ft 3/4" copper tubing 1-3/4" curb stop

same caldwell stop box same 3/4c5/8 lead-cop adapt.xxs

same Fig 413

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

10/15/97: tap reamed

## METER HISTORY

[illegible]

## CHARGE OUTS

36

APPLICATION No.: 12081 5/8" H lead

TAP CLEARED 9013-1460

LOCATION: 1-3 Bay St.

OWNER: Jules &amp; Mary Pacheco

MEASURES:

5/8"

H lead

Apr. 28, 1908

N from

Bay

1.0 ft.

E from W line

Dartmouth

7.5 ft.

N from E line

Main house

3.8 ft.

- ✓ 3/27/90: Renewed from  $\frac{1}{2}$ ' outside curb stop to prop line  
 Stock: 10ft. 3/4" copper tubing  
 1-3/4" curb stop 1-Caldwell stop box  
 2- 3/4x5/8 lead to cop adapt. xxs=====

6/5/90 Pressure O.K. cold water  
 cold water problem Hansen-Silva 6/5/90

6/5/90 checked pressure - Hansen Silva cold water o.k.

problem seems to be with hot water.

- ✓ 6/16/94: Renewed from main to a point 1ft  
 Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs  
 1-3/4x5/8 Fig 413  
 =====

- ✓ June 27, 1995: Blocked tap was reamed using existing stock  
 by W Walsh cement liners J.Rodrigues

DATE

BEF.

AFT.

REMARKS

6-8-  
94

942106 434

6/16/94: tap reamed

## METER HISTORY

## CHARGE OUTS

[illegible]