

37

APPLICATION No.: 1214

TAP CLEARED 8427-1277

LOCATION: 141 Acushnet Ave.

OWNER: Valentine Farming

MEASURES: 5/8" H lead Nov. 20, 1872
 N from Grinnell St. 157.2 ft.
 E from W line Avenue 6.6 ft.
 S from N line house 8.7 ft.

Oct. 17, 1980: Renewed from main to prop. line.

14.0 ft.-3/4" copper

1-1/2" x 3/4" Fig. 413 Tap reamed

1-5/8" x 3/4" lead-cop. adapt. XXS

1-3/4" curb stop 1-Caldwell stop box

July 5, 1984 - Renewed from 1/2 ft. outside curb stop
 to inside cellar. (10 ft. ins.)

16 ft. 6 in. - 3/4" copper tubing; 1 stop box;

CHECKED FOR LEAK ON 1-11-89 BY D. DUARTE (NO LEAK)

77 77 77 77 1-19-89 77 JR.

SEWER WATER COMING FROM VENT AT NO 143
 INTO SIDEWALK D.P.W. CONTACTED.

DATE

BEF.

AFT.

REMARKS

OCT 17 1980

Reamed

OCT 17 1980 Owner refused
 to go into cellar.

METER HISTORY

CHARGE OUTS

[illegible]