

APPLICATION No.: 12156 5/8" L lead

TAP CLEARED

LOCATION: 184 Belleville Rd.

OWNER: J.L. Poisson

MEASURES: 5/8"

L lead

June 30, 1908

W from

Acushnet Ave.

491.7 ft.

N from S line

Belleville Rd.

9.0 ft.

W from E line

House

3.3 ft.

Nov. 19, 1976 Renewed from 6" outside curb stop to the property line.

7½ ft. - 3/4" Copper tubing      3/4" Curb Stop

Caldwell Stop Box 3/4" x 5/8" lead to copper  
adapt. XS

— — —

Sept.13,1996: Street reconstruction      Tilcon excavation  
REnewed from main to prop line

Stock: 18ft 3/4" copper tubing same curb stop

1- Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4x5/8 Fig 413      Insp. M Rose III

4/2/2018: Lead service line replacement program phase 1  
P. Gioioso & Sons contractor:

TYPE CU, Diameter 1", Water Pressure 58

Distance from main to curb stop N/A

Distance curb to meter 27.3'

Distance from curb face to curb stop 1.5'

Depth of service 5.0'

Total length of new pipe installed 30.3'

Corporation replaced NO Size N/A  
Ball valve furnished YES Size 1"

\_\_\_\_\_

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

9/13/96: tap reamed

[illegible]

### CHARGE OUTS

