

341 Ashley Blvd APPLICATION No.: 12163

TAP CLEARED

LOCATION:

OWNER:

31-313

MEASURES:

June 4, 1908

S from Tinkham St 21.0'

E from W line Ashley Blvd 9.0'

N from S line house 9.3'

1" COPPER

5-31-2018: Lead service line replacement
program phase 1: TYPE: CU, Diameter 1
water pressure 65 contractor: P. Gioioso

Distance from main to curb stop 10'

Distance curb stop to meter 15.0'

Distance from curb face to curb stop 1.5'

Depth of service 3.7'- public 10ft

Total length of new pipe installed 28.0'
private 18'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball valve furnished: YES Size 1"

Remarks: 10' main corp to curb stop

14.0' curb stop to house

1.0' house to meter

3.0' whip

28.0' ft - 1" copper installed

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

