

APPLICATION No.: 12169

TAP CLEARED ✓

LOCATION: 203 Hawthorne Cor. Tremont

OWNER: Mary G Conroy

MEASURES:

5/8"

Copper

06-06-1908

E from Tremont

58.0 ft.

S from N line Hawthorn

9.0 ft.

E from W line house

5.0 ft.

Aug. 24, 1965 Renewed service from $\frac{1}{2}$ ' outside curb stop to 3 ft. inside curb stop. $3\frac{1}{2}$ ' $\frac{3}{4}$ " copper tubing

$\frac{3}{4}$ " cop. to cop. stop, fig. 415

2 lbs. wiping solder

1/17/92: Renewed from $\frac{1}{2}$ ' outside curb stop to prop line

Stock: 9ft $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop

1- Caldwell stop box 2- $\frac{3}{4}$ x $\frac{5}{8}$ lead-cop adapt.xs

6-21-01 Renewed from main to curb stop. Stock:

25 ft. - $\frac{3}{4}$ " Copper tubing, 1 - $\frac{3}{4}$ " Curb Stop,

1- Caldwell Stop Box, 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413.

4/21/11 Bad leak in front yard, letter sent to owner 4/28/11

5/25/11 - RJ Canessa renewed water service from curb stop to meter (Owner charged \$185 (\$45 shut-oo, \$70 inspection fee, \$25 - $\frac{3}{4}$ " meter blank & couplings & \$45 turn on)

Inspected by Percy. Additional measures

W from E line House

21.0

S from S line House

41.0

Main to Property Line

34.0

Pipe inside property

47.0

DATE

BEF.

AFT.

REMARKS

1-17-92 9203 2700

6-21-01 Tap reamed

[illegible]

CHARGE OUTS

