

APPLICATION No.: 12181

TAP CLEARED 8950-1007

LOCATION: 77 Pierce

OWNER: Pauline Showsky

MEASURES: 5/8" 3/4 Copper

N from	Elm	23.0 ft.
E from W line	Pierce	6.7 ft.
S from N line	House	2.0 ft.

DATE

BEF.

AFT.

REMARKS

9111-1857

3/13/91: TAP REAMED

Complaint of yellow water Sample Clear 3/11/91 Decant
Clear

Dec. 12, 1989 renewed from 1 ft. outside curb stop to a point 2 ft.
3 ft. - 3/4" copper tubing 1 - 3/4" curb stop 1 stop box
2 - 5/8" x 3/4" lead to cop adapt XS

3/13/91: Renewed from main to inside cellar.
10 ft. ins. prop line Stock: 28ft. 3/4" copper tubing
1- 3/4" curb stop same Caldwell stop box
1- 3/4x5/8 Fig.413=====

6/16/05 Renewed from newly installed 8" main to a point 9.0 ft.
Stock: 9.0 ft. 3/4" copper tubing; 3/4" cop-cop cplg., comp; 3/4"
corp. tap

[illegible]

CHARGE OUTS