

APPLICATION No.: 12200

TAP CLEARED 8612-311A

LOCATION: 166 Hathaway

OWNER: George Quintin

MEASURES: E from Brook St 163.5 ft.
N from S line Hathaway 9.0 ft.
E from W line house 8.2 ft.

April 11, 1962 Checked for service leak the above date and found no service leak; instead, we found surface water entering the cellar of this house

3/21/86: Renewed from main to cellar. Stock: 25.0 ft.
3/4" copper tubing 1 - 5/8 Fig.413 1 - 3/4" curb stop
1 - Caldwell stop box. =====

DATE

BEF.

AFT.

REMARKS

3/21/86: TAP REAMED

[illegible]

CHARGE OUTS

[illegible]