

APPLICATION No.: ~~12022~~ # ~~12202~~

## TAP CLEARED

LOCATION: 49 Howard Ave. N.S. E. of Belle Ave.OWNER: Felix Rochleau

MEASURES:

5/8" now all copper

01-01-1913

W from

River Rd.

269.0 ft.

S from N line

Howard Ave.

9.0 ft.

W from E line

house

9.0 ft.

Sept. 17, 1952 Renewed from tap to a point 11 ft. on street side of curb stop  
 60 ft. - 3/4" copper tubing 3/4" x 3/4" cplg., fig. 413  
 1# wiping solder  
 Location of corporation - <sup>5</sup>/<sub>8</sub> ft. east of curb stop

Nov. 19, 1975 Repaired leak by cutting in a new curb stop 3/4" - at a point 11 ft. in front of the main.  
 This curb stop was left in the on position & buried.  
 3/4" curb stop

no 12/3/87

francis 6/26/91 must have n.s.

10/6/07 - Renewed from main to property line  
 Stock: 17 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell stop box; 1 - 5/8" x 3/4" lead to cop adapt.; 1 - 3/4" Fig 413  
 J. Velez

9/29/11 - City crew renewed water service from curb stop to meter

26 ft - 3/4" copper tubing; 1 Caldwell stop box  
 Foreman: Danny Perry

DATE

BEF.

AFT.

REMARKS

10/5/07

2007-401-0134

9/20/11 11:15

2011-3809311



[illegible]

## CHARGE OUTS

APPLICATION No. \_\_\_\_\_

LOCATION:

OWNER:

31-313

9/24/12 - City crew repaired 6 ft section of water  
service damaged by NStar Gas  
6 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 - 3/4"  
cop to cop cplg. Foreman: J. Medeiros

Foreman: J. Medeiros

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS



[illegible]

## This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf from an old book. The paper has a slightly textured appearance with some minor discoloration and small dark spots, possibly from foxing or handling over time. A vertical crease is visible down the center of the page, and there are some faint, dark marks near the top right corner. The overall tone is a warm, off-white or light beige.