

APPLICATION No.: 12241

TAP CLEARED

D 2752

LOCATION: 309 Earle

OWNER: Jose F. Medeiros

MEASURES:

5/8"

E from	Brook	182.9
S from N line	Earle	9.0
E from W line	House	14.5

July 13, 1964 Renewed service from curb stop to property line.
8' 3/4" copper tubing 3/4" cop to cop. stop, fig. 415
1 wiping solder (one lb.)

Renewed service from 6" outside curb stop to 3 ft. inside curb stop
3 1/2 ft. 3/4" copper tubing 3/4" cop. to cop. stop, fig 415
2 lbs. wiping solder

April 13, 1981: Renewed from curb stop to inside of cellar.
19 ft.-3/4" Copper tubing (12' out) used same curb stop & stop
box.

JUL 29 1981 - Renewed from main to 15" from main.
15"-3/4" copper; 5/8" x 3/4" lead-cop. adapt. XS;
5/8" x 3/4" Fig. 413;

NOTE: SEE BACK OF CARD FOR MORE REPAIRS & INFO ON SERVICE

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

JUL 29 1981

Reamed

9/10/04

Tap reamed

[illegible]

3/4" curb stop: