

APPLICATION No.: 12298

LOCATION: 172 - 174 Hatch St

OWNER:

31-313

MEASURES: E X Acushnet Ave 85.2 ft

N X S Line Hatch St	8.8 ft
---------------------	--------

W X E Line House 12.3 ft

1" Copper Service

05/09/2019 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 10.5

Distance curb stop to meter (ft) 16.8

Distance from curb face to curb stop (ft) 2.0

Depth of service (ft) 4.7

Total length of new pipe installed (ft) 27.3

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: yes size 1"

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]

[illegible]