

12324

APPLICATION No.:

TAP CLEARED

LOCATION: 139 Dartmouth St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

Sept 22, 1908

N from Oak St 124.7'

E from W line Dartmouth St 7.5'

S from N line house 9.0'

1" COPPER SERVICE

11-29-2018: Lead service line replacement program

Phase 1, Contractor: P. Gioioso &amp; Sons

TYPE: CU, Diameter 1 inch, Water Pressure 90

Distance from main to curb stop 28.6'

Distance curb stop to meter 17'

Distance from curb face to curb stop 1.5'

Depth of service 3.5'

Total length of new pipe installed 28.6'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished: NO Size 3/4"

Remarks: 1- 3/4" union installed 1 LF outside curb stop

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

## CHARGE OUTS

