

APPLICATION No.: 12349

LOCATION: 127 Maple E. of Atlantic St.

OWNER: Alice A. Miller

MEASURES: 5/8"

E from  
S from N line  
E from W line

Atlantic  
Maple  
House

78.3 ft.  
9.0 ft.  
3.2 ft.

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

|         |        |              |
|---------|--------|--------------|
| 7/11/05 | 830 AM | 2005-2900502 |
|---------|--------|--------------|

|         |     |        |
|---------|-----|--------|
| 7/11/05 | Tap | Reamed |
|---------|-----|--------|

5/21/91 11:10 A.M. call very low pressure  
+ black water Quanta checked it out  
1:00 P.M. Snyu + Porto went back remove  
meter and flushed from street through  
services to no avail. Later on we found  
out a fire flow test was being taken  
at the Mental State Building and we  
were never notified.

OVER FOR MORE INFO

[illegible]

## CHARGE OUTS

[illegible]