

APPLICATION No.: 12400

TAP CLEARED

LOCATION: 157 Crapo St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

10/2/64 Ream

MEASURES:

October 31, 1908

S X Mosher St 49.0 ft

E X W line Crapo St 7.3 ft

S X N line House 9.0

08/06/2019 Lead service line replacement program

Phase 1, Contractor P Gioioso and Son

Type CU, Diameter (in)1, Water pressure 100

Distance from main to curb stop (ft) 6

Distance curb stop to meter (ft) 17

Distance from curb face to curb stop (ft) 0.8

Depth of service (ft) 4.3

Total length of new pipe installed (ft) 17

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes 1"

Remarks: 1-3/4" union installed 1 ft outside curb stop

[illegible]