

APPLICATION No.: 12402

TAP CLEARED 8726-1404

LOCATION: Nash Rd. 122

OWNER: Georgianna Ricard

MEASURES: 5/8"

W from

Diman

209.4 ft.

N from S line

Nash R.d

9.5 ft.

W from E line

House

14.6 ft.

6/24/87: Renewed from 1/2' outside curb stop to prop line
stock: 8ft. 3/4" copper tubing 1-3/4" curb stop
1 - caldwell stop box 1-3/4 x 5/8 lead to cop adapt. xxs
=====

Complained sidewalk cut 8/24/87

*7-26-89 METER ROOM CHECKED LEAK NEAR METER.
LEAK IS UNDER FOUNDATION + LOOKS LIKE
THEY TRIED TO REPAIR UNDER GROUND
WITH RUBBER!*

8/31/89: Renewed from main to inside cellar (6ft. ins. prop line)
Stock: 25ft. 3/4" copper tubing 1-3/4" curb stop
1 - Caldwell stop box 1-3/4x5/8 Fig.413
=====

DATE

BEF.

AFT.

8/31 REMARKS

8935-3628

8/31/89: TAP REAMED

[illegible]

CHARGE OUTS

[illegible]