

1243

✓

93-97 Union

Jack Michelson

3/4"

JOHNNY CAKE Hill

First

69.9 ft.

Union

8.4 ft.

bldg.

15.3 ft.

June 22, 1962 Renewed from main to 3 ft. inside the curb stop.
24 ft. of 3/4" copper tubing 1 3/4" x 1" cop. to I.F.cplg.
1 Caldwell stop box, complete 1 3/4" cop. to cop. stop
1 lb. wiping solder

August 20, 1957 Renewed from a point 4 ft. outside curb stop
to a point 7 ft. outside curb stop.
3 ft. of 3/4" copper tubing 2 lbs. wiping solder

June 2, 1969 Renewed from the new 12" main to a point 1 ft. inside
of the curb stop.
23 ft. of 3/4" copper tubing 1 3/4" Hays tap
1 3/4" Hays curb stop 1 Buffalo stop box
1 wipe joint Mueller B-100 tapping machine

March 3, 1971 Renewed from the curb stop to inside the meter pit.
9 ft. of 3/4" copper tubing

Sept 3, 1987 Changed to 1" copper from meter pit to utility room on west side of building, by way of front door & under floor. Two sweat couplings used one 9.0 ft. N x meter pit . Another on west side of door way in line with S.L. building. Plumber cooked these couplings & copper around it. They are very suspect to leaks.

[illegible]