

APPLICATION No.: 12448

TAP CLEARED

LOCATION: 187 Newton Cor. Hillman

DATE

BEF.

AFT.

REMARKS

OWNER: Wm H Jenkins

2/1/74

Reamed

MEASURES:

5/8"

4-18-02 Tap reamed

W from

Newton

28.5 ft.

N from S line

Hillman

9.0 ft.

E from W line

body of house

1.8 ft.

Feb. 1, 1974 Renewed from main to a point 6½ ft.  
from the main.

6½ ft. - 3/4" Copper tubing 3/4" x 3/4" Fig. 413  
1 wipe joint

-----

November 28, 1975 Renewed from 6" outside the curb  
stop to inside the cellar.

13½ ft. 3/4" copper tubing

1 3/4" x 3/4" Hays corp. stop

1 wipe joint

Sidewalk curb: 8 x 3 Blacktop

-----

August 16, 1976 Repaired leak on outside wipe joint.  
Cut out wipe joint & replaced.

6" - 3/4" Copper tubing 5/8" x 3/4" lead to copper adapt. XS

-----

4-18-02 Renewed from main to curb stop. 3ft in front curb  
stop; Stock: 13ft-3/4" Copper; 1 3/4" Curb Stop;  
1-Caldwell Stop Box; 1-3/4"x 3/4" cop to cop cplg., comp;  
1- 3/4" Corporation Tap; 1-10'x3/4" service saddle;

[illegible]

## CHARGE OUTS

[illegible]