

2071

APPLICATION No.: 12472

TAP CLEARED

LOCATION: ~~2075~~ Purchase N.W. Cor. Cedar Grove

OWNER: Fire Dept.

MEASURES: 2"	12-31-1898		
W from N line	Purchase	100.0 ft.	100.2
S from N line	Cedar Grove	6.9 ft.	6.2
E from W line	building	20.0 ft.	18.7

Jan. 27, 28, 1964 Renewed from the main to a point  
 1 ft. inside 2" gate valve in sidewalk. A new 2"  
 Gate Valve was installed. The old 2" cast iron pipe and the 2" gate  
 valve were moved & returned to shop for junk,  
 15 ft. - 2" Copper tubing  
 9 ft. - 1" Copper tubing  
 3 - 1" Corporation  
 2 1" reused corp. cplg.  
 1 1/4" x 1" cop to i.f. cplg. fig. 413  
 4 - 2" cop to 2" male couplings  
 2" Darling Gate Valve, threaded hubs \* O-R.  
 1 - 1" x 1" x 1" 3 way branch  
 1 Caldwell gate box R-144

July 23, 1970 Renewed from sidewalk gate to inside  
 cellar. - 20 ft. - 2" copper tubing

[illegible]