

APPLICATION No.: 1 2549

TAP CLEARED 87 42- ✓

LOCATION: 18 Peckham

OWNER: Wm. D &amp; S.S. Eldridge

MEASURES: <sup>5/8" - L.L.</sup>  
 W from County 76.9 ft.  
 N from S line Peckham 9.2 ft.  
 W from E line House 3.0 ft.

-----  
 December 29, 1961 Renewed from a point 1 ft. outside curb stop  
 to 1 ft. inside curb stop  
 1 3/4" cop. to cop. stop 2 lbs. wiping solder  
 -----

Feb. 29, 1980: Renewed from main to a point 10" from main.  
 10 inches - 3/4" copper  
 1-5/8" x 3/4" Fig. 413  
 1-5/8" x 3/4" lead-cop. adapt. XS  
 -----

10-13-87 Old curb stop broken off at foot, replaced with new box  
 Stock:  
 1-Caldwell stop box

8/9/06 Renewed from 1 ft. outside curb stop to inside cellar.  
 (6 ft. inside property line) Stock: 16 ft. 3/4" copper tubing;  
 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead-cop adapt. XXS

NOTE: Found 6" sewer service sewer leaking from joints..piece of  
 clay missing on top, replaced 6 ft section with PVC pipe Bento  
 -----

See other side

[illegible]

## CHARGE OUTS

[illegible]