| APPLICATION No.: 12614 | TAP CLEARED V | | | | |
|--|---------------|------|------|---------|--|
| LOCATION: 352 Davis St | DATE | BEF. | AFT. | REMARKS | |
| OWNER: | | | | | |
| MEASURES: E X Church St 211.2 ft N X S line Davis ST 9.0 ft W X E line House 1.0 ft 1 Copper Service 06/04/2018 Lead Service Line Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter (in) 1, Water pressure 70 Distance from main to curb stop (ft) 10.5 Distance curb stop to meter (ft) 15.5 Distance from curb face to curb stop (ft) 2.5 Depth of service (ft) 3.6 Total length of new pipe installed (ft) 29.0 Public 10.5 ft Private 18.5 ft Curb stop replaced: yes size 1" Corporation replaced: yes size 1" Ball valve furnished: yes size 1" | | | | | |

