

Notation on Bottom APPLICATION No.: 12665 6" Copper
LOCATION: 37 Brook St. FIRE SUPPLY

OWNER: Dawson Brewery Co. MAY 10, 1909

MEASURES: 6" Copper C.I.
S from Tallman 83.7 ft.
E from W line Brook 11.5 ft.
N from S line Bldg. 10.8 ft.
To shut off this service - first service #22138
8" gate Valve must be shut off.

1/8/01 Rec'd call from Fernando Morais - per fire dept they must
activate fire supply to bldg.
1/9/01 Checked 6" gate on Brook St. - Owner to cap pipe inside
so that gate can be opened to check.

8/3/10 - New measurements for gate valve -6" C.I.

S from S line Tallman St	83.7
E from W line Brook St	6.5
N from S line Building	28.0
E from E line Building	6.5
main to Property line	14.0
Pipe inside property	3.0

8/3/10 - JLC Construction replaced gate valve to this
service, see new measures above. Owner charged \$70
inspection fee. Inspected by Percy Reynolds

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

DATE	BEF.	AFT.	REMARKS
			Gate Valve shut off on Holly St., E x W line Ashley Blvd. 15.3'
			Dec. 2, 1980
			The 8" Gate valve on Holly St. E x W line Ashley Blvd. 15.3' was shut off on Dec. 2, 1980 by John Medeiros. A leak was heard running on service #12665 - 6" on Brook St. This 12" Private main formerly supplied #22138 - 6" - 17 Brook St. #9623 - 4" - 27 Brook St. #12665 - 6" - 37 Brook St. FS. Dawson Brewery Co.

METER HISTORY

CHARGE OUTS

[illegible]

837

APPLICATION No. 12665 8" Cast Iron

TAP CLEARED

LOCATION:

W.S. Brook St. opposite Holly St.

OWNER:

FIRE SUPPLY

MEASURES:

8" Cast Iron 12-1-46
8" Darling Gate; 8" C.I. Gate Box 233#
S from S line Tallman 89.4 ft.
E from W line Brook 7.8 ft.
N from S line office 22.0 ft.
Shutoff this service before shutting off #12665.

DATE

BEF.

AFT.

REMARKS

11/2/04 SERVICE CUT OFF 1143 DE

