

LOCATION: 150 Hathaway St

APPLICATION No.: 12673

TAP CLEARED

OWNER:

31-313

MEASURES: W X Ashley Blvd 263.3 ft
N X S line Hathaway St 9.0 ft
E X W line House 10.3 ft
1" Copper Service
07/10/2018 Lead Service Line Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 75
Distance from main to curb stop (ft) 10.0
Distance curb stop to meter (ft) 20.8
Distance from curb face to curb stop (ft) 2.5
Depth of service (ft) 5.0
Total length of new pipe installed (ft) 20.8
Curb stop replaced: no size 3/4"
Corporation replaced: no size 3/4"
Ball valve furnished: yes size 1"
Remarks: 1"-3/4" union installed 1.0 lf outside
curb stop

DATE

BEF.

AFT.

REMARKS

11/9/93 Tap Rea

[illegible]