

APPLICATION No.: 12713 5/8"

TAP CLEARED

A2611

LOCATION: 284 Collette St.

OWNER: John Marwur

DATE

BEF.

AFT.

REMARKS

2-8-07

8:00

2007-0606-2724

MEASURES: W from Ashley Blvd. 186.4 ft.
N from S line Collette 9.0 ft.
E from W line House 12.0 ft.

1/31/78: Renewed from 1 ft. outside curbstop to prop. line.
6 ft.-3/4" copper; 3/4" curb stop; Caldwell stop box;
2-3/4" x 3/4" lead to cop. adapt. XS;

2/8/07 Renewed from main to curb stop. Stock: 8 ft. 3/4" copper
tubing; 3/4" curb stop; Caldwell stop box Bento

1" Copper Service

06/26/2018 Lead Service Line Replacement Program

Phase 1 Contractor P Gioioso and Son

Type CU, Diameter (in) 1, Water Pressure 70

Distance from main to curb stop ft N/A

Distance curb stop to meter (ft) 19.5

Distance from curb face to curb stop 2.5

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 22.5

Curb stop replaced no


Corporation replaced no

Ball Valve furnished yes size 1"

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
3/11/69		5/8	Rock Mag	20272759					

CHARGE OUTS



COLLETTA ST