

Service Killed

APPLICATION No.: 1283

TAP CLEARED

LOCATION: 325 County St. (24 Allen St) (DUPLICATE)

OWNER:

LOST ORIGINAL

MEASURES: 5/8"

OFF IN STREET 7-27-39

S from	Allen St.	32.3	30.5 ft.
E from W line	County St.	4.0	9.1 ft.
N from S line	House	13.8	14.7 ft.

DATE

BEF.

AFT.

REMARKS

6/5/75

Reamed

h.t.
towel

✓ June 5, 1975 Renewed from the main to the property line.
16 ft. - 3/4" Copper tubing 3/4" Curb Stop
Caldwell Stop Box 3/4" X 3/4" Fig. 413
5/8" x 3/4" lead connector - - -

WATER WAS LEFT OFF AT CURB STOP.

8/8/2012 LEONE ENGINEERING killed this service
at the tap - Inspected by Percy

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 1283 5/8"

TAP CLEARED

LOCATION: 325 County St.

OWNER: Audena Audette

MEASURES: 5/8"

S from

E from W line

N from S line

Offin street 7/27/39

Allen

County

House

30.5 ft.

9.1 ft.

14.7 ft.

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS