	APPLICATION No.:	12877		TAP		ED 8813-1340
LOCATION: 65 Jouvet	te St.		DATE	BEF.	AFT.	REMARKS
OWNER: John N. Canto, Jr.						
MEASURES: 5/8"	H lead	Aug.16,1908				1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
E from	Crapo St.	437.5 ft.				
S from N line	Jouvette St.	8.8 ft.				
W from E line	house	4.5 ft.				
W from E line house 4.5 ft.  3/29/88 Renewed from ½' outside curb stop to ins cellar (5ft ins prop line) 15ft-3/4" copper tubing,1-3/4" curb stop, 1-Caldwell stop box 1-5/8x3/4 lead to cop adapt xxs  10/23/2018 water service repair -Main to c/s 26ft 3/4 copper tubing, Cast Iron Stop Box, 3/4 curb stop Valve, 5/8 corp adapter Daniel Perry Ronnie Aguier  1" Copper Service 07/30/2019 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Disameter1in, Waterpressure 100 Distance from main to curb stop (ft) 25 DIstance from curb stop to meter (ft) N/A Distance from curb face to curb stop (ft) 3 Depth of service (ft) 4 Total length of new pipe installed (ft) 25 Curb stop replaced: yes size 1" Corporation replaced: yes size 1" Ball valve replaced: No						
BRADBURY-WARING, INC.						