

APPLICATION No.: ~~12859~~ 12895

TAP CLEARED ✓

LOCATION: 33 Sherman St.

OWNER: Mary J. Mello

MEASURES:

5/8" H lead Aug. 23, 1909
W from County St. 294.4 ft.
S from N line Sherman St. 7.0 ft.
W from E line House 1.7 ft.

7/3/89: Renewed from newly installed 6" ductile main to a
point 1 ft. Brito Const. supplied & installed stock:
1 ft. 3/4" copper tubing 1-3/4x5/8 lead to cop adapt. xxs
1 - 3/4" corporation tap. Brito Const. to maintain trench
Insp. M Rose

OFF 2-3-94 Vacant House
M. Rose III pipes burst

1/12/07 Renewed from main to inside cellar. (6 ft.
inside property line) Stock: 32 ft. 3/4" copper tubing;
3/4" curb stop; Caldwell stop box; Tap reamed
(NOTE: existing new 3/4" tap on new main) Bento

[illegible]

CHARGE OUTS

[illegible]