

APPLICATION No.: 12958

TAP CLEARED

LOCATION: 69 Crapo St.OWNER: Joseph T. Correia

DATE BEF. AFT. REMARKS ✓

7/17/95: tap reamed

MEASURES: 5/8" H lead Sept. 27, 1909

S from Thompson St. 97.0 ft.

E from W line Crapo St. 6.8 ft.

S from N line house 13.8 ft.

Dec. 16, 1968 Renewed from the main to a point 1 ft. from main
1 ft. of 3/4" copper tubing 2 wiped joints
1 reused 5/8" corporation

Sept. 27, 1973 Renewed from 6" outside curb stop to
inside cellar.

13 ft. - 3/4" Copper tubing (6 ft. inside)

3/4" Hays curb stop 1 # wipeing solder

- - -

CRAPO ST RECONSTRUCTION

July 17, 1995: Todesca Corp renewed serv. from main to ins. cellar
6.0 ft ins. prop line Cont supplied all stock & will maintain
trench Stock: 19.6ft 3/4" copper tubing 1-3/4" curb stop
1-stop box 1-3/4x5/8 Fig 413

Insp. Dennis Monty

NOTE: broke & repaired sewer 6" south of water serv.
ADDITIONAL MEASURES:

S x N side house 12.0 ft

N x S side house 17.0 ft

[illegible]

CHARGE OUTS

[illegible]