

APPLICATION No.: 12970

TAP CLEARED



LOCATION: 280 Earle

OWNER: Ann M. Kenny

MEASURES:

DATE BEF. AFT. REMARKS

12/10/85: TAP REAMED

8/17/04 G+E
VET AT+T 2:15 2004-340-4274

8/18/04 Tap reamed

5/8"

W from	Adshley Blvd.	165.7
N from S line	Earle	9.0
E from Wline	House	13.0

Dec. 1, 1959 Renewed from $\frac{1}{2}$ ft. outside curb stop to
2 $\frac{1}{2}$ ft. inside curb stop.
3 ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " cop to cop stop
2# wiping solder

- - -

12/10/85: Renewed from main to a point 1.4 ft.

Stock: 1.4 ft. $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop
adapt. xs 1- $\frac{3}{4}$ x $\frac{5}{8}$ Fig. 413

=====

8/18/04 Renewed from main to inside cellar. (11 ft. ins. prop.
line). Stock: 28 ft. $\frac{3}{4}$ " copper tubing; $\frac{3}{4}$ " curb stop; Caldwell
stop box; $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413 tap reamed
Turn over for more repairs ...

[illegible]

ferncos; 41 ft. 6" PVC